

Fire Extinguisher Safety Inspection Log Form Sample

This **fire extinguisher safety inspection log form sample** helps ensure regular checks are conducted to maintain equipment functionality and compliance with safety standards. It provides a structured way to record inspection dates, results, and necessary maintenance actions. Using this form promotes a safer environment by keeping fire extinguishers ready for emergency use.

Extinguisher Location	Extinguisher Type	Serial Number	Inspection Date	Inspected By	Condition (Pass/Fail)	Comments/Action Taken
Building A - 1st Floor Lobby	ABC Dry Chemical	123456				
Building B - Kitchen	CO ₂	654321				
Warehouse - Near Exit	Water	456789				

Note: Inspectors should check for correct pressure, intact pin and seal, legible label, visible instructions, and unobstructed access. Record all actions and replace or service any extinguisher that does not pass inspection.